

## **NFPD Station #1 Capitol Maintenance Needs**

**Phone System**      New phone system is needed as our current system has failed several times and is pieced together

**Garage Doors**

5601, 5624, 5641, and 5617, Bay doors all need to have the bottom "Safety Stop Sensor Pad" replaced  
Technician Don, "Garage Door Systems" 303-772-1448, evaluated all 3 stations and will e-mail me his findings and a rough estimate.

**Roof**

Inspection scheduled for Monday the 18<sup>th</sup>.

**St-1 Upstairs**

Ceiling around the vent over Kitchen table, needs to be spackled and or repaired.

Staircase Railing is loose

Kitchen Floor Tiles need to be Sealed

Painting is needed

Screens replacement with metal screens

**St-1 Atrium**

Floor needs sealed and North window replacement.

**Jim's Office**

Carpet is needed

## **NFPD Station #2 Capitol Maintenance Needs**

### **Road**

Entrance and surrounding area of station needs road maintenance and graded for better infrastructure and longevity.

### **Roof**

Inspection scheduled for Monday the 18<sup>th</sup>

### **Garage Doors**

No mechanical repairs needed at this time, just lube and regular maintenance.

## **NFPD Station #3 Capitol Maintenance Needs**

### **Toilet**

Non-Operational condition

Deep cleaning

### **Garage Doors**

1<sup>st</sup> Bay Door – Left side weatherstripping and Wooden Trim is broken.

Center Bay Door – Left side Weatherstripping needs to be replaced.

Both Doors are functional at this time with no replacements needed. All doors need lubed.

### **Outside**

Front-West Green Wooden Trim broken off.

All outside lights are non-operational with missing bulbs noted.

Needed Sign noted

### **Roof**

Inspection scheduled for Monday the 18<sup>th</sup>